



太阳能产品认证证书

证书编号：CQC19024212290

申请人名称及地址

深圳古瑞瓦特新能源股份有限公司
深圳市宝安区石岩街道龙腾社区光辉路 28 号加域工业区办公楼 A 栋一层东、三层，厂房 B 栋

制造商名称及地址

深圳古瑞瓦特新能源股份有限公司
深圳市宝安区石岩街道龙腾社区光辉路 28 号加域工业区办公楼 A 栋一层东、三层，厂房 B 栋

生产企业名称及地址

深圳古瑞瓦特新能源股份有限公司 (V021430)
深圳市宝安区石岩街道上屋村西边岭加域公司工业区 A、B、C 栋

产品名称和系列、规格、型号

光伏并网逆变器

MIN 3000TL-X, MIN 3600TL-X, MIN 4200TL-X, MIN 4600TL-X, MIN 5000TL-X, MIN 6000TL-X (见附件)

产品标准和技术要求

NB/T32004-2013(IIIa, 不含低电压穿越试验)

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC33-461239-2013 认证规则的要求，特发此证。

发证日期：2019 年 01 月 22 日

本证书的有效性依据发证机构的定期监督获得保持。



主任：_____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

T 0012568



太阳能产品认证证书

附 录

第 1 页 共 2 页

证书编号: CQC19024212290

纸 号: 12568

MIN 3000TL-X

直流输入:MPPT 电压范围 80V-500Vdc, 最大直流输入电压 500Vdc, 最大输入电流 12.5A*2;
交流输出:~, 230V, 50Hz, Max. 14.3A, 额定交流输出功率 3kW;

MIN 3600TL-X

直流输入:MPPT 电压范围 80V-550Vdc, 最大直流输入电压 550Vdc, 最大输入电流 12.5A*2;
交流输出:~, 230V, 50Hz, Max. 17.2A, 额定交流输出功率 3.6kW;

MIN 4200TL-X

直流输入:MPPT 电压范围 80V-550Vdc, 最大直流输入电压 550Vdc, 最大输入电流 12.5A*2;
交流输出:~, 230V, 50Hz, Max. 20.0A, 额定交流输出功率 4.2kW;

MIN 4600TL-X

直流输入:MPPT 电压范围 80V-550Vdc, 最大直流输入电压 550Vdc, 最大输入电流 12.5A*2;
交流输出:~, 230V, 50Hz, Max. 22.0A, 额定交流输出功率 4.6kW;

MIN 5000TL-X

直流输入:MPPT 电压范围 80V-550Vdc, 最大直流输入电压 550Vdc, 最大输入电流 12.5A*2;
交流输出:~, 230V, 50Hz, Max. 23.9A, 额定交流输出功率 5kW;

注: 此附录与证书同时使用时有效。



主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



太阳能产品认证证书

附 录

证书编号: CQC19024212290

第 2 页 共 2 页

纸 号: 12568

MIN 6000TL-X

直流输入: MPPT 电压范围 80V-550Vdc, 最大直流输入电压 550Vdc, 最大输入电流 12.5A*2;
交流输出: ~, 230V, 50Hz, Max. 28.7A, 额定交流输出功率 6kW。

注: 此附录与证书同时使用时有效。



主任: 陆 楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC19024212290

NAME AND ADDRESS OF THE APPLICANT

Shenzhen Growatt New Energy Technology Co., Ltd.
1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng
Community, Shiyan Street, Baoan District, Shenzhen, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shenzhen Growatt New Energy Technology Co., Ltd.
1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng
Community, Shiyan Street, Baoan District, Shenzhen, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shenzhen Growatt New Energy Technology Co., Ltd. (V021430)
Building A,B,C, Jiayu Industrial Zone, Xibianling, Shangwu Village, Shiyan, Baoan District, Shenzhen, China

PRODUCT NAME, MODEL AND SPECIFICATION

PV GRID INVERTER

MIN 3000TL-X, MIN 3600TL-X, MIN 4200TL-X, MIN 4600TL-X, MIN 5000TL-X, MIN 6000TL-X (See
Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T32004-2013(IIIa, Without Low Voltage Ride Through Test)

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC33-461239-2013 .

Valid from: Jan.22,2019

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body.



President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

T 0012568